

P.O. Box 1090 - NL-2280 CB Rijswijk Lange Kleiweg 5 - NL-2288 GH Rijswijk The Netherlands +31 88 3473 723 nederland@efectis.com

CLASSIFICATION

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1:2009

Classification no. 2013-Efectis-R0165c/LNE/BKJX

Sponsor COT by

Postbus 2113

NL-2002 CC Haarlem The Netherlands

Product name ZINGA 2 x 90 µm, coating on steel

Prepared by Efectis Nederland BV

Notified body no. 1234

Author(s) E. van der Laan M.Sc.

A.J. Lock

Project number 2013165

Date of issue May 8, 2013

Number of pages 5

All rights reserved

No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland. Submitting the report for inspection to parties who have a direct interest is permitted.



Efectis Nederland Report 2013-Efectis-R0165c/LNE/BKJX May 8, 2013 COT bv

CLASSIFICATION

1. INTRODUCTION

This classification report defines the classification assigned to ZINGA 2 x 90 μ m, coating on steel in accordance with the procedures given in EN 13501-1:2007+A1:2009.

2. DETAILS OF CLASSIFIED PRODUCT

2.1. GENERAL

The product, **ZINGA 2** \times 90 μ m, coating on steel, is defined as a coating on steel.

2.2. PRODUCT DESCRIPTION

Product description: Film Galvanising system

2.3. IMPORTER/MANUFACTURER

COT bv Postbus 2113 NL-2002 CC Haarlem The Netherlands ZINGAmetall byba

3. STANDARDS, REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

3.1. REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method	
Efectis Nederland BV	COT bv	2013-Efectis-R0165a	EN ISO 11925-2:2010	
The Netherlands	The Netherlands	2013-Efectis-R0165b	EN 13823:2010	



3.2. TEST RESULTS

Test method and test number	Parameter	No. tests	Results			
			Continuous parameter - mean (m)	Compliance with parameters		
EN-ISO 11925-2						
surface flame impingement	Fs ≤150 mm	6	29	-		
	Ignition of filter paper		-	Compliant		
Edge flame impingement	Fs ≤150 mm	6	14	-		
	Ignition of filter paper		-	Compliant		
	Ignition of filter paper		-	Compliant		
EN 13823						
	FIGRA0.2MJ [W/s]		0	-		
FIGRA0.4MJ [W/s] THR600s [MJ] LFS < edge SMOGRA [m2/s2] TSP600s [m2] Flaming debris - flaming ≤ 10 s - flaming > 10 s	FIGRA0.4MJ [W/s]	3	0	-		
	THR600s [MJ]		0.2	-		
			•	Compliant		
			0.0	-		
			21	-		
		-	Compliant Compliant			

3.3. CLASSIFICATION CRITERIA

Classification criteria of the Single Burning Item (SBI) test						
Class	Fire	Class	Smoke			
A2	FIGRA _{0.2 MJ} \leq 120 W/s LFS $<$ edge of the long wing specimen THR _{600s} \leq 7,5 MJ	s1	$\begin{array}{c} SMOGRA \leq 30 \ m^2/s^2 \\ TSP_{600s} \leq 50 \ m^2 \end{array}$			
В	FIGRA _{0.2 MJ} \leq 120 W/s LFS $<$ edge of the long wing specimen THR _{600s} \leq 7,5 MJ	s2	$\begin{aligned} &SMOGRA \leq 180 \ m^2/s^2 \\ &TSP_{600s} \leq 200 \ m^2 \end{aligned}$			
	FIGRA _{0.4 MJ} ≤ 250 W/s	Class	Droplets			
С	LFS < edge of the long wing specimen	d0	No flaming droplets/particles			
	THR _{600s} ≤ 15 MJ	d1	Flaming droplets/particles < 10 s			
D	FIGRA ≤ 750 W/s	d2	Not d0 or d1			

CLASSIFICATION



CLASSIFICATION AND FIELD OF APPLICATION

4.1. REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2007+ A1:2009.

4.2. CLASSIFICATION

The product, ZINGA 2 x 90 µm, coating on steel, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

S1

The additional classification in relation to flaming droplets / particles is:

d0

Reaction to fire classification: B - s1, d0

4.3. FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness 2 x 90 µm

Coverage 0.97 kg/m² Surface density

Zinc content in dry layer >96%, Other properties

Unlimited pot and shelf life, Provides cathodic protection

This classification is valid for the following end use applications:

Substrate Non-combustible

(class A1/A2 according to EN 13238:2010)

4.4. DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

There are no limitations in time on the validity of this report.



Efectis Nederland Report 2013-Efectis-R0165c/LNE/BKJX May 8, 2013 COT bv

CLASSIFICATION

5. LIMITATIONS

This classification document does not represent type approval or certification of the product.

Yours faithfully,

E. van der Laan M.Sc. Project leader reaction to fire A.J. Lock Project leader reaction to fire